EC Type-Examination Certificate

Product Safety
Functional
Safety

TÜVRheinland®
CERTIFIED

www.tuv.com
ID 0600000000

Reg.-No.: 01/205/5072.03/25

Product tested	Safety relays	**Certificate holder**	H. ZANDER GmbH & Co. KG Am Gut Wolf 15 52070 Aachen Germany
Type designation	SR4C Details see Revision List		
Codes and standards	EN ISO 13849-1:2023 EN ISO 13849-2:2012		EN 61508 Parts 1-7:2010
Intended application	The undelayed contacts of the SR4C fulfill the requirements for Cat. 4 and PL e acc. to EN ISO 13849-1 and SIL 3 acc. to EN 61508. The time-delayed switch-off contacts of the SR4C fulfil the requirements for Cat. 3 and PL e acc. to EN ISO 13849-1 and SIL 3 acc. to EN 61508. The Safety relays SR4C can be used in safety applications up to SIL 3 (EN 61508) and PL e (EN ISO 13849-1).		
Specific requirements	The instructions of the associated Installation and Operating Manual shall be considered.		

It is confirmed that the product under test complies with the requirements for machines defined in Annex I of the EC Directive 2006/42/EC.

Valid until 2030-11-06

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/M 279.05/25 dated 2025-11-03.
This certificate is valid only for products which are identical with the product tested.

TÜVRheinland 0035 Notified Body

Köln, 2025-11-06

Notified Body for Machinery, NB 0035

Sabine Wiegand

Dipl.-Ing. (FH) Sabine Wiegand

www.fs-products.com
www.tuv.com

TÜVRheinland®
Precisely Right.

10/222 12. 12 E A4 ® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.

TÜV Rheinland Industrie Service GmbH, Am Grauen Stein, 51105 Köln / Germany
Tel.: +49 221 806-2434, Fax: +49 221 806-1354, E-Mail: industrie-service@de.tuv.com