

MINOS SL Ordering Code

Type designation

MINOS	SL		
-------	----	--	--

Type

Application

- 1 Dual-Channel emergency stop or safety door monitoring with short circuit monitoring
- 2 Light curtains, contact amplification, OSSD or single-channel emergency stop

PL / SILCL

- D Up to PL d / SILCL 2
No test pulses at the safe output
- E Up to PL e / SILCL 3
Test pulses at the safe output enable error detection during operation

Order No.

4	7	2	8		
---	---	---	---	--	--

Variant SLxD / SLxE

- 0 SLxD
- 2 SLxE

Application, Start behavior and Terminals

- 0 SL1y with manual start and tensil spring terminals
- 1 SL1y with manual start and screw terminals
- 2 SL1y with automatic start an tensil spring terminals
- 3 SL1y with automatic start and screw terminals
- 4 SL2y with manual start and tensil spring terminals
- 5 SL2y with manual start and screw terminals
- 6 SL2y with automatic start and tensil spring terminals
- 7 SL2y with automatic start and screw terminals

Example:

472826: MINOS SL2E with automatic Start and tensil spring terminals

