

EC Type-Examination Certificate



Product Safety
Functional
Safety

www.tuv.com
ID 060000000


Reg.-No.: 01/205/5463.02/18

Product tested	Safety relay combinations	Certificate holder	H. ZANDER GmbH & Co. KG Am Gut Wolf 15 52070 Aachen Germany
Type designation	SRLC, SR2C, SK3D, SR3A(D), SR3C, SR3C-AC, SR3D, TE-OR3, TE-OR3D		
Codes and standards	EN ISO 13849-1:2015 EN 62061:2005 + AC:2010 + A1:2013 + A2:2015	IEC 61508 Parts 1-7:2010 EN 50178:1997	
Intended application	The safety relays SR2C, SK3D, SR3A(D), SR3C, SR3C-AC, SR3D, TE-OR3 and TE-OR3D fulfil the requirements for SIL 3 (IEC 61508, EN 62061 und IEC 61511) and Cat. 4 / PL e (EN ISO 13849-1). The safety relay SRLC fulfils the requirements for SIL 2 and Cat. 3 / PL d. Further the variants SR3AD, SK3D, SR3D and TE-OR3D also fulfil the requirements of EN 746-2 and EN 50156-1 and can therefore be used in safety shutdown applications for furnaces operating in continuous mode up to SIL 3.		
Specific requirements	The provisions defined in the user manual and the conditions of the test report shall be maintained.		

It is confirmed that the products under test comply with the requirements for machines defined in Annex I of the EC Directive 2006/42/EC.

Valid until 2023-11-27

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 1161.02/18 dated 2018-11-27.
This certificate is valid only for products which are identical with the product tested.



Köln, 2018-11-27

Notified Body for Machinery, NB 0035

Dipl.-Ing. Eberhard Frejno

www.fs-products.com
www.tuv.com

TÜVRheinland[®]
Precisely Right.